

**REPORTED TO** Regional District of Thompson Nicola  
300 - 465 Victoria Street  
Kamloops, BC V2C 2A9

**TEL** 1-250-377-8673  
**FAX** 1-250-374-6489

**ATTENTION** Denise Roberts

**WORK ORDER** 3051645

**PO NUMBER** 23929  
**PROJECT** Pritchard CWS  
**PROJECT INFO**

**RECEIVED / TEMP** May-29-13 09:15 / 12.0 °C  
**REPORTED** Jun-05-13  
**COC NUMBER** 40837.5581

**General Comments:**

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Issued By:

**Jennifer Shanko, ASCT**  
Administration Coordinator, Kelowna

**Please contact CARO if more information is needed or to provide feedback on our services.**

**Locations:**

#110 4011 Viking Way  
Richmond, BC V6V 2K9  
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N  
Kelowna, BC V1X 5C3  
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue  
Edmonton, AB T5S 1H7  
Tel: 780-489-9100 Fax: 780-489-9700

[www.caro.ca](http://www.caro.ca)

**REPORTED TO PROJECT** Regional District of Thompson Nicola  
Pritchard CWS

**WORK ORDER REPORTED** 3051645  
Jun-05-13

Analysis Description	Method Reference (* = modified from)		Location
	Preparation	Analysis	
Alkalinity, speciated	N/A	APHA 2320 B	Kelowna
Ammonia-N, total colorimetric	N/A	APHA 4500-NH3 G	Kelowna
Chloride in Water by IC	N/A	APHA 4110 B	Kelowna
Colour, True at 410 nm	N/A	APHA 2120 C *	Kelowna
Conductivity in Water	N/A	APHA 2510 B	Kelowna
Dissolved Metals	APHA 3030 B	APHA 3125 B	Richmond
Fluoride in Water by IC	N/A	APHA 4110 B	Kelowna
Hardness as CaCO3 (CALC)	N/A	APHA 2340 B	Richmond
Nitrate-N in Water by IC	N/A	APHA 4110 B	Kelowna
Nitrite-N in Water by IC	N/A	APHA 4110 B	Kelowna
Sulfate in Water by IC	N/A	APHA 4110 B	Kelowna
Total Dissolved Solids	N/A	APHA 2540 C	Kelowna
Total Recoverable Metals	APHA 3030E *	APHA 3125 B	Richmond
Transmissivity at 254nm	N/A	APHA 5910 B	Kelowna
Trihalomethanes	EPA 5030B / 5021A	APHA 6200 B	Richmond

*Note: The numbers in brackets represent the year that the method was published/approved*

**Method Reference Descriptions:**

APHA Standard Methods for the Examination of Water and Wastewater, American Public Health Association  
EPA United States Environmental Protection Agency Test Methods

**Glossary of Terms:**

MRL Method Reporting Limit  
< Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences  
AO Aesthetic objective  
MAC Maximum acceptable concentration (health-related guideline)  
% Percent W/W  
Color Unit Colour referenced against a platinum cobalt standard  
mg/L Milligrams per litre  
uS/cm Microsiemens per centimeter

**REPORTED TO PROJECT** Regional District of Thompson Nicola  
Pritchard CWS

**WORK ORDER REPORTED** 3051645  
Jun-05-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

**Anions**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10** F1

Alkalinity, Total as CaCO <sub>3</sub>	37		1	mg/L	N/A	May-30-13	
Alkalinity, Phenolphthalein as CaCO <sub>3</sub>	< 1		1	mg/L	N/A	May-30-13	
Alkalinity, Carbonate as CaCO <sub>3</sub>	< 1		1	mg/L	N/A	May-30-13	
Alkalinity, Bicarbonate as CaCO <sub>3</sub>	37		1	mg/L	N/A	May-30-13	
Alkalinity, Hydroxide as CaCO <sub>3</sub>	< 1		1	mg/L	N/A	May-30-13	
Chloride	3.15	AO ≤ 250	0.10	mg/L	N/A	May-31-13	
Fluoride	< 0.10	MAC = 1.5	0.10	mg/L	N/A	May-31-13	
Nitrogen, Nitrate as N	0.046	MAC = 10	0.010	mg/L	N/A	May-31-13	
Nitrogen, Nitrite as N	0.026	MAC = 1	0.010	mg/L	N/A	May-31-13	
Sulfate	4.9	AO ≤ 500	1.0	mg/L	N/A	May-31-13	

**General Parameters**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10** F1

Colour, True	< 5	AO ≤ 15	5	Color Unit	N/A	May-31-13	
Conductivity (EC)	95		2	uS/cm	N/A	May-30-13	
Nitrogen, Ammonia as N, Total	< 0.020		0.020	mg/L	N/A	May-31-13	
Solids, Total Dissolved	62	AO ≤ 500	5	mg/L	N/A	Jun-03-13	
UV Transmittance @ 254nm	93.0		0.1	%	N/A	May-31-13	

**Calculated Parameters**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10** F1

Total Trihalomethanes	0.054	0.1	0.004	mg/L	N/A	N/A	
Total Trihalomethanes (as CHCl <sub>3</sub> )	0.054		0.003	mg/L	N/A	N/A	
Hardness, Total (Total as CaCO <sub>3</sub> )	42.1		5.0	mg/L	N/A	N/A	
Hardness, Total (Diss. as CaCO <sub>3</sub> )	40.2		5.0	mg/L	N/A	N/A	
Nitrogen, Nitrate+Nitrite as N	0.072		0.020	mg/L	N/A	N/A	

**Dissolved Metals**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10** F1

Aluminum, dissolved	< 0.05		0.05	mg/L	N/A	May-31-13	
Antimony, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Arsenic, dissolved	< 0.005		0.005	mg/L	N/A	May-31-13	
Barium, dissolved	< 0.05		0.05	mg/L	N/A	May-31-13	
Beryllium, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Bismuth, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Boron, dissolved	< 0.04		0.04	mg/L	N/A	May-31-13	
Cadmium, dissolved	< 0.0001		0.0001	mg/L	N/A	May-31-13	
Calcium, dissolved	13		2	mg/L	N/A	May-31-13	
Chromium, dissolved	0.005		0.005	mg/L	N/A	May-31-13	
Cobalt, dissolved	< 0.0005		0.0005	mg/L	N/A	May-31-13	
Copper, dissolved	0.005		0.002	mg/L	N/A	May-31-13	
Iron, dissolved	< 0.1		0.1	mg/L	N/A	May-31-13	

**REPORTED TO PROJECT** Regional District of Thompson Nicola  
Pritchard CWS

**WORK ORDER REPORTED** 3051645  
Jun-05-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

**Dissolved Metals, Continued**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10, Continued**

F1

Lead, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Lithium, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Magnesium, dissolved	<b>2.0</b>		0.1	mg/L	N/A	May-31-13	
Manganese, dissolved	< 0.002		0.002	mg/L	N/A	May-31-13	
Mercury, dissolved	< 0.0002		0.0002	mg/L	N/A	May-31-13	
Molybdenum, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Nickel, dissolved	< 0.002		0.002	mg/L	N/A	May-31-13	
Phosphorus, dissolved	< 0.2		0.2	mg/L	N/A	May-31-13	
Potassium, dissolved	<b>1.0</b>		0.2	mg/L	N/A	May-31-13	
Selenium, dissolved	< 0.005		0.005	mg/L	N/A	May-31-13	
Silicon, dissolved	< 5		5	mg/L	N/A	May-31-13	
Silver, dissolved	< 0.0005		0.0005	mg/L	N/A	May-31-13	
Sodium, dissolved	<b>3.5</b>		0.2	mg/L	N/A	May-31-13	
Strontium, dissolved	<b>0.08</b>		0.01	mg/L	N/A	May-31-13	
Sulfur, dissolved	< 10		10	mg/L	N/A	May-31-13	
Tellurium, dissolved	< 0.002		0.002	mg/L	N/A	May-31-13	
Thallium, dissolved	< 0.0002		0.0002	mg/L	N/A	May-31-13	
Thorium, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	
Tin, dissolved	< 0.002		0.002	mg/L	N/A	May-31-13	
Titanium, dissolved	< 0.05		0.05	mg/L	N/A	May-31-13	
Uranium, dissolved	<b>0.0002</b>		0.0002	mg/L	N/A	May-31-13	
Vanadium, dissolved	< 0.01		0.01	mg/L	N/A	May-31-13	
Zinc, dissolved	< 0.04		0.04	mg/L	N/A	May-31-13	
Zirconium, dissolved	< 0.001		0.001	mg/L	N/A	May-31-13	

**Total Recoverable Metals**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10**

F1

Aluminum, total	<b>0.07</b>	AO ≤ 0.1	0.05	mg/L	May-30-13	Jun-01-13	
Antimony, total	< 0.001	MAC = 0.006	0.001	mg/L	May-30-13	Jun-01-13	
Arsenic, total	< 0.005	MAC = 0.01	0.005	mg/L	May-30-13	Jun-01-13	
Barium, total	< 0.05	MAC = 1	0.05	mg/L	May-30-13	Jun-01-13	
Beryllium, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	
Bismuth, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	
Boron, total	< 0.04	MAC = 5	0.04	mg/L	May-30-13	Jun-01-13	
Cadmium, total	< 0.0001	MAC = 0.005	0.0001	mg/L	May-30-13	Jun-01-13	
Calcium, total	<b>13</b>		2	mg/L	May-30-13	Jun-01-13	
Chromium, total	< 0.005	MAC = 0.05	0.005	mg/L	May-30-13	Jun-01-13	
Cobalt, total	< 0.0005		0.0005	mg/L	May-30-13	Jun-01-13	
Copper, total	<b>0.006</b>	AO ≤ 1	0.002	mg/L	May-30-13	Jun-01-13	
Iron, total	<b>0.1</b>	AO ≤ 0.3	0.1	mg/L	May-30-13	Jun-01-13	
Lead, total	< 0.001	MAC = 0.01	0.001	mg/L	May-30-13	Jun-01-13	
Lithium, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	
Magnesium, total	<b>2.1</b>		0.1	mg/L	May-30-13	Jun-01-13	
Manganese, total	<b>0.003</b>	AO ≤ 0.05	0.002	mg/L	May-30-13	Jun-01-13	

**REPORTED TO PROJECT** Regional District of Thompson Nicola  
Pritchard CWS

**WORK ORDER REPORTED** 3051645  
Jun-05-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

**Total Recoverable Metals, Continued**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10, Continued**

F1

Mercury, total	< 0.0002	MAC = 0.001	0.0002	mg/L	May-30-13	Jun-01-13	
Molybdenum, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	
Nickel, total	< 0.002		0.002	mg/L	May-30-13	Jun-01-13	
Phosphorus, total	< 0.2		0.2	mg/L	May-30-13	Jun-01-13	
Potassium, total	<b>1.0</b>		0.2	mg/L	May-30-13	Jun-01-13	
Selenium, total	< 0.005	MAC = 0.01	0.005	mg/L	May-30-13	Jun-01-13	
Silicon, total	< 5		5	mg/L	May-30-13	Jun-01-13	
Silver, total	< 0.0005		0.0005	mg/L	May-30-13	Jun-01-13	
Sodium, total	<b>3.6</b>	AO ≤ 200	0.2	mg/L	May-30-13	Jun-01-13	
Strontium, total	<b>0.08</b>		0.01	mg/L	May-30-13	Jun-01-13	
Sulfur, total	<b>12</b>		10	mg/L	May-30-13	Jun-01-13	
Tellurium, total	< 0.002		0.002	mg/L	May-30-13	Jun-01-13	
Thallium, total	< 0.0002		0.0002	mg/L	May-30-13	Jun-01-13	
Thorium, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	
Tin, total	< 0.002		0.002	mg/L	May-30-13	Jun-01-13	
Titanium, total	< 0.05		0.05	mg/L	May-30-13	Jun-01-13	
Uranium, total	<b>0.0003</b>	MAC = 0.02	0.0002	mg/L	May-30-13	Jun-01-13	
Vanadium, total	< 0.01		0.01	mg/L	May-30-13	Jun-01-13	
Zinc, total	< 0.04	AO ≤ 5	0.04	mg/L	May-30-13	Jun-01-13	
Zirconium, total	< 0.001		0.001	mg/L	May-30-13	Jun-01-13	

**Volatile Organic Compounds (VOC)**

**Sample ID: Pritchard CWS (3051645-01) [Water] Sampled: May-28-13 12:10**

F1

Bromodichloromethane	< 0.001		0.001	mg/L	N/A	May-31-13	
Bromoform	< 0.001		0.001	mg/L	N/A	May-31-13	
Chloroform	<b>0.054</b>		0.001	mg/L	N/A	May-31-13	
Dibromochloromethane	< 0.001		0.001	mg/L	N/A	May-31-13	
Surrogate: Toluene-d8	83 %		80-120		N/A	May-31-13	
Surrogate: 4-Bromofluorobenzene	81 %		80-120		N/A	May-31-13	

**Sample / Analysis Qualifiers:**

F1 The sample was not field-filtered and was therefore filtered through a 0.45 um membrane in the laboratory and preserved with HNO3 prior to analysis for dissolved metals.