

REPORTED TO Regional District of Thompson Nicola
300 - 465 Victoria Street
Kamloops, BC V2C 2A9

TEL (250) 377-8673
FAX (250) 374-6489

ATTENTION Shawn Kratchmer

WORK ORDER 5061393

PO NUMBER 26415
PROJECT Black Pines CWS
PROJECT INFO

RECEIVED / TEMP Jun-18-15 09:40 / 15°C
REPORTED Jul-06-15
COC NUMBER B15932

General Comments:

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Authorized By:

Ed Hoppe, B.Sc., P.Chem.
Division Manager, Kelowna

Please contact CARO if more information is needed or to provide feedback on our services.

Locations:

#110 4011 Viking Way
Richmond, BC V6V 2K9
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N
Kelowna, BC V1X 5C3
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue
Edmonton, AB T5S 1H7
Tel: 780-489-9100 Fax: 780-489-9700

www.caro.ca

REPORTED TO PROJECT Regional District of Thompson Nicola
Black Pines CWS

WORK ORDER REPORTED 5061393
Jul-06-15

Analysis Description	Method Reference	Technique	Location
Alkalinity in Water (Speciated)	APHA 2320 B	Titration with H2SO4 to pH 4.5	Kelowna
Anions in Water by IC	APHA 4110 B	Ion Chromatography with Chemical Suppression of Eluent Conductivity	Kelowna
Colour, True	APHA 2120 C	Spectrophotometry (456 nm)	Kelowna
Conductivity in Water	APHA 2510 B	Conductivity Meter	Kelowna
Hardness (as CaCO3)	APHA 2340 B	Calculation	N/A
Total Ammonia-N in Water	APHA 4500-NH3 G*	Automated Colorimetry (Phenate)	Kelowna
Total Dissolved Solids (Gravimetric)	APHA 2540 C*	Gravimetry (Dried at 103-105C)	Kelowna
Total Recoverable Metals	APHA 3030E* / APHA 3125 B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Transmissivity at 254 nm	APHA 5910 B	Ultraviolet Absorption	Kelowna
Trihalomethanes	EPA 5030B / APHA 6200 B	Purge&Trap / Purge and Trap Capillary Column GC-MSD	Richmond

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Method Reference Descriptions:

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation
 EPA United States Environmental Protection Agency Test Methods

Glossary of Terms:

MRL Method Reporting Limit
 < Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
 % T Percent Transmittance
 CU Colour Units (referenced against a platinum cobalt standard)
 mg/L Milligrams per litre
 µS/cm Microsiemens per centimetre

Standards / Guidelines Referenced in this Report:

Guidelines for Canadian Drinking Water Quality (Oct 2014)
 Website: http://www.hc-sc.gc.ca/ewh-semt/alt_formats/pdf/pubs/water-eau/sum_guide-res_recom/sum_guide-res_recom-eng.pdf

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

REPORTED TO PROJECT Regional District of Thompson Nicola
Black Pines CWS

WORK ORDER REPORTED 5061393
Jul-06-15

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Black Pines CWS (5061393-01) [Water] Sampled: Jun-17-15 10:30

PRES

Anions

Chloride	0.18	AO ≤ 250	0.10	mg/L	N/A	Jun-20-15	
Fluoride	< 0.10	MAC = 1.5	0.10	mg/L	N/A	Jun-20-15	
Nitrate as N	0.100	MAC = 10	0.010	mg/L	N/A	Jun-20-15	
Nitrite as N	< 0.010	MAC = 1	0.010	mg/L	N/A	Jun-20-15	
Sulfate	6.0	AO ≤ 500	1.0	mg/L	N/A	Jun-20-15	

General Parameters

Alkalinity, Total as CaCO3	31	N/A	1	mg/L	N/A	Jun-19-15	
Alkalinity, Phenolphthalein as CaCO3	< 1	N/A	1	mg/L	N/A	Jun-19-15	
Alkalinity, Bicarbonate as CaCO3	31	N/A	1	mg/L	N/A	Jun-19-15	
Alkalinity, Carbonate as CaCO3	< 1	N/A	1	mg/L	N/A	Jun-19-15	
Alkalinity, Hydroxide as CaCO3	< 1	N/A	1	mg/L	N/A	Jun-19-15	
Colour, True	7	AO ≤ 15	5	CU	N/A	Jun-19-15	
Conductivity (EC)	71	N/A	2	µS/cm	N/A	Jun-19-15	
Ammonia as N, Total	< 0.020	N/A	0.020	mg/L	N/A	Jun-23-15	
Solids, Total Dissolved	45	AO ≤ 500	10	mg/L	N/A	Jun-22-15	
UV Transmittance @ 254nm	90.1	N/A	0.1	% T	N/A	Jun-19-15	

Calculated Parameters

Total Trihalomethanes	< 0.004	MAC = 0.1	0.004	mg/L	N/A	N/A	
Hardness, Total (Total as CaCO3)	35.5	N/A	5.0	mg/L	N/A	N/A	
Nitrate+Nitrite as N	0.100	N/A	0.020	mg/L	N/A	N/A	

Total Recoverable Metals

Aluminum, total	0.26	OG < 0.1	0.05	mg/L	Jun-23-15	Jun-24-15	
Antimony, total	< 0.001	MAC = 0.006	0.001	mg/L	Jun-23-15	Jun-24-15	
Arsenic, total	< 0.005	MAC = 0.01	0.005	mg/L	Jun-23-15	Jun-24-15	
Barium, total	< 0.05	MAC = 1	0.05	mg/L	Jun-23-15	Jun-24-15	
Beryllium, total	< 0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	
Bismuth, total	< 0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	
Boron, total	< 0.04	MAC = 5	0.04	mg/L	Jun-23-15	Jun-24-15	
Cadmium, total	< 0.0001	MAC = 0.005	0.0001	mg/L	Jun-23-15	Jun-24-15	
Calcium, total	11.3	N/A	2.0	mg/L	Jun-23-15	Jun-24-15	
Chromium, total	< 0.005	MAC = 0.05	0.005	mg/L	Jun-23-15	Jun-24-15	
Cobalt, total	< 0.0005	N/A	0.0005	mg/L	Jun-23-15	Jun-24-15	
Copper, total	0.007	AO ≤ 1	0.002	mg/L	Jun-23-15	Jun-24-15	
Iron, total	0.44	AO ≤ 0.3	0.10	mg/L	Jun-23-15	Jun-24-15	
Lead, total	0.001	MAC = 0.01	0.001	mg/L	Jun-23-15	Jun-24-15	
Lithium, total	0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	
Magnesium, total	1.8	N/A	0.1	mg/L	Jun-23-15	Jun-24-15	
Manganese, total	0.012	AO ≤ 0.05	0.002	mg/L	Jun-23-15	Jun-24-15	
Molybdenum, total	< 0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	
Nickel, total	< 0.002	N/A	0.002	mg/L	Jun-23-15	Jun-24-15	
Phosphorus, total	< 0.2	N/A	0.2	mg/L	Jun-23-15	Jun-24-15	
Potassium, total	0.7	N/A	0.2	mg/L	Jun-23-15	Jun-24-15	
Selenium, total	< 0.005	MAC = 0.05	0.005	mg/L	Jun-23-15	Jun-24-15	
Silicon, total	< 5	N/A	5	mg/L	Jun-23-15	Jun-24-15	

REPORTED TO PROJECT Regional District of Thompson Nicola
Black Pines CWS

WORK ORDER REPORTED 5061393
Jul-06-15

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Black Pines CWS (5061393-01) [Water] Sampled: Jun-17-15 10:30, Continued

PRES

Total Recoverable Metals, Continued

Silver, total	< 0.0005	N/A	0.0005	mg/L	Jun-23-15	Jun-24-15	
Sodium, total	1.1	AO ≤ 200	0.2	mg/L	Jun-23-15	Jun-24-15	
Strontium, total	0.07	N/A	0.01	mg/L	Jun-23-15	Jun-24-15	
Sulfur, total	< 10	N/A	10	mg/L	Jun-23-15	Jun-24-15	
Tellurium, total	< 0.002	N/A	0.002	mg/L	Jun-23-15	Jun-24-15	
Thallium, total	< 0.0002	N/A	0.0002	mg/L	Jun-23-15	Jun-24-15	
Thorium, total	< 0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	
Tin, total	< 0.002	N/A	0.002	mg/L	Jun-23-15	Jun-24-15	
Titanium, total	< 0.05	N/A	0.05	mg/L	Jun-23-15	Jun-24-15	
Uranium, total	0.0003	MAC = 0.02	0.0002	mg/L	Jun-23-15	Jun-24-15	
Vanadium, total	< 0.01	N/A	0.01	mg/L	Jun-23-15	Jun-24-15	
Zinc, total	< 0.04	AO ≤ 5	0.04	mg/L	Jun-23-15	Jun-24-15	
Zirconium, total	< 0.001	N/A	0.001	mg/L	Jun-23-15	Jun-24-15	

Volatile Organic Compounds (VOC)

Bromodichloromethane	< 0.001	N/A	0.001	mg/L	N/A	Jun-22-15	
Bromoform	< 0.001	N/A	0.001	mg/L	N/A	Jun-22-15	
Chloroform	< 0.001	N/A	0.001	mg/L	N/A	Jun-22-15	
Dibromochloromethane	< 0.001	N/A	0.001	mg/L	N/A	Jun-22-15	
Surrogate: Toluene-d8	97		70-130	%	N/A	Jun-22-15	
Surrogate: 4-Bromofluorobenzene	87		70-130	%	N/A	Jun-22-15	

Sample / Analysis Qualifiers:

PRES Sample has been preserved for NH3 in the laboratory and the holding time has been extended.