

REPORTED TO Regional District of Thompson Nicola
300 - 465 Victoria Street
Kamloops, BC V2C 2A9

TEL (250) 377-6284
FAX (250) 374-6489

ATTENTION Shawn Kratchmer

WORK ORDER 6120869

PO NUMBER

RECEIVED / TEMP 2016-12-13 09:00 / 4°C

PROJECT Maple Mission CWS

REPORTED 2016-12-21

PROJECT INFO

COC NUMBER B49227

General Comments:

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Authorized By:

Ed Hoppe, B.Sc., P.Chem.
Division Manager, Kelowna

If you have any questions or concerns, please contact your Account Manager:
Jennifer Shanko, ASCT (jshanko@caro.ca)

Locations:

#110 4011 Viking Way
Richmond, BC V6V 2K9
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N
Kelowna, BC V1X 5C3
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue
Edmonton, AB T5S 1H7
Tel: 780-489-9100 Fax: 780-489-9700

www.caro.ca

REPORTED TO PROJECT Regional District of Thompson Nicola
Maple Mission CWS

WORK ORDER REPORTED 6120869
2016-12-21

Analysis Description	Method Reference	Technique	Location
Alkalinity in Water	APHA 2320 B*	Titration with H2SO4	Kelowna
Ammonia, Total in Water	APHA 4500-NH3 G*	Automated Colorimetry (Phenate)	Kelowna
Anions by IC in Water	APHA 4110 B	Ion Chromatography with Chemical Suppression of Eluent Conductivity	Kelowna
Colour, True in Water	APHA 2120 C	Spectrophotometry (456 nm)	Kelowna
Conductivity in Water	APHA 2510 B	Conductivity Meter	Kelowna
Dissolved Metals by ICPMS in Water	APHA 3030 B / APHA 3125 B	0.45 µm Filtration / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Hardness (as CaCO3) in Water	APHA 2340 B	Calculation: 2.497 [diss Ca] + 4.118 [diss Mg]	N/A
Hardness (as CaCO3) in Water	APHA 2340 B*	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Estimated)	N/A
Mercury, total by CVAFS in Water	EPA 245.7*	BrCl2 Oxidation / Cold Vapor Atomic Fluorescence Spectrometry (CVAFS)	Richmond
Solids, Total Dissolved in Water	APHA 2540 C*	Gravimetry (Dried at 103-105C)	Kelowna
Total Metals by ICPMS in Water	APHA 3030E* / APHA 3125 B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Transmissivity at 254 nm in Water	APHA 5910 B*	Ultraviolet Absorption	Kelowna
Trihalomethanes in Water	EPA 5030B / APHA 6200 B	Purge&Trap / Purge and Trap Capillary Column GC-MSD	Richmond

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Method Reference Descriptions:

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation
EPA United States Environmental Protection Agency Test Methods

Glossary of Terms:

MRL Method Reporting Limit
< Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
AO Aesthetic objective
MAC Maximum acceptable concentration (health based)
OG Operational guideline (treated water)
% T Percent Transmittance
CU Colour Units (referenced against a platinum cobalt standard)
mg/L Milligrams per litre
µS/cm Microsiemens per centimetre

Standards / Guidelines Referenced in this Report:

Guidelines for Canadian Drinking Water Quality (Oct 2014)

Website: http://www.hc-sc.gc.ca/ewh-semt/alt_formats/pdf/pubs/water-eau/sum_guide-res_recom/sum_guide-res_recom-eng.pdf

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

REPORTED TO PROJECT Regional District of Thompson Nicola
Maple Mission CWS

WORK ORDER REPORTED 6120869
2016-12-21

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Maple Mission CWS - Pumphouse (6120869-01) [Water] Sampled: 2016-12-12 11:30

**F1, FILT,
PRES**

Anions

Chloride	1.45	AO ≤ 250	0.10	mg/L	N/A	2016-12-15	
Fluoride	< 0.10	MAC = 1.5	0.10	mg/L	N/A	2016-12-15	
Nitrate (as N)	0.044	MAC = 10	0.010	mg/L	N/A	2016-12-15	
Nitrite (as N)	< 0.010	MAC = 1	0.010	mg/L	N/A	2016-12-15	
Sulfate	23.2	AO ≤ 500	1.0	mg/L	N/A	2016-12-15	

General Parameters

Alkalinity, Total (as CaCO3)	220	N/A	2	mg/L	N/A	2016-12-14	
Alkalinity, Phenolphthalein (as CaCO3)	< 1	N/A	2	mg/L	N/A	2016-12-14	
Alkalinity, Bicarbonate (as CaCO3)	220	N/A	2	mg/L	N/A	2016-12-14	
Alkalinity, Carbonate (as CaCO3)	< 1	N/A	2	mg/L	N/A	2016-12-14	
Alkalinity, Hydroxide (as CaCO3)	< 1	N/A	2	mg/L	N/A	2016-12-14	
Ammonia, Total (as N)	0.044	N/A	0.020	mg/L	N/A	2016-12-15	
Colour, True	< 5	AO ≤ 15	5	CU	N/A	2016-12-14	
Conductivity (EC)	439	N/A	2	µS/cm	N/A	2016-12-14	
Solids, Total Dissolved	247	AO ≤ 500	10	mg/L	N/A	2016-12-16	
UV Transmittance @ 254nm	98.0	N/A	0.1	% T	N/A	2016-12-15	

Calculated Parameters

Total Trihalomethanes	0.007	MAC = 0.1	0.004	mg/L	N/A	N/A	
Hardness, Total (as CaCO3)	235	N/A	0.50	mg/L	N/A	N/A	
Nitrate+Nitrite (as N)	0.044	N/A	0.020	mg/L	N/A	N/A	

Dissolved Metals

Aluminum, dissolved	< 0.005	N/A	0.005	mg/L	N/A	2016-12-21	
Antimony, dissolved	< 0.0001	N/A	0.0001	mg/L	N/A	2016-12-21	
Arsenic, dissolved	< 0.0005	N/A	0.0005	mg/L	N/A	2016-12-21	
Barium, dissolved	< 0.005	N/A	0.005	mg/L	N/A	2016-12-21	
Beryllium, dissolved	< 0.0001	N/A	0.0001	mg/L	N/A	2016-12-21	
Bismuth, dissolved	< 0.0001	N/A	0.0001	mg/L	N/A	2016-12-21	
Boron, dissolved	0.016	N/A	0.004	mg/L	N/A	2016-12-21	
Cadmium, dissolved	< 0.00001	N/A	0.00001	mg/L	N/A	2016-12-21	
Calcium, dissolved	49.7	N/A	0.2	mg/L	N/A	2016-12-21	
Chromium, dissolved	< 0.0005	N/A	0.0005	mg/L	N/A	2016-12-21	
Cobalt, dissolved	< 0.00005	N/A	0.00005	mg/L	N/A	2016-12-21	
Copper, dissolved	0.0066	N/A	0.0002	mg/L	N/A	2016-12-21	
Iron, dissolved	< 0.010	N/A	0.010	mg/L	N/A	2016-12-21	
Lead, dissolved	0.0002	N/A	0.0001	mg/L	N/A	2016-12-21	
Lithium, dissolved	0.0033	N/A	0.0001	mg/L	N/A	2016-12-21	
Magnesium, dissolved	27.0	N/A	0.01	mg/L	N/A	2016-12-21	
Manganese, dissolved	< 0.0002	N/A	0.0002	mg/L	N/A	2016-12-21	
Mercury, dissolved	0.00004	N/A	0.00002	mg/L	N/A	2016-12-21	CT5
Molybdenum, dissolved	0.0002	N/A	0.0001	mg/L	N/A	2016-12-21	
Nickel, dissolved	< 0.0002	N/A	0.0002	mg/L	N/A	2016-12-21	
Phosphorus, dissolved	< 0.02	N/A	0.02	mg/L	N/A	2016-12-21	
Potassium, dissolved	0.77	N/A	0.02	mg/L	N/A	2016-12-21	

REPORTED TO PROJECT Regional District of Thompson Nicola
Maple Mission CWS

WORK ORDER REPORTED 6120869
2016-12-21

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Maple Mission CWS - Pumphouse (6120869-01) [Water] Sampled: 2016-12-12 11:30, Continued

F1, FILT, PRES

Dissolved Metals, Continued

Selenium, dissolved	< 0.0005	N/A	0.0005	mg/L	N/A	2016-12-21	
Silicon, dissolved	6.1	N/A	0.5	mg/L	N/A	2016-12-21	
Silver, dissolved	< 0.00005	N/A	0.00005	mg/L	N/A	2016-12-21	
Sodium, dissolved	4.18	N/A	0.02	mg/L	N/A	2016-12-21	
Strontium, dissolved	0.406	N/A	0.001	mg/L	N/A	2016-12-21	
Sulfur, dissolved	5	N/A	1	mg/L	N/A	2016-12-21	
Tellurium, dissolved	< 0.0002	N/A	0.0002	mg/L	N/A	2016-12-21	
Thallium, dissolved	< 0.00002	N/A	0.00002	mg/L	N/A	2016-12-21	
Thorium, dissolved	< 0.0001	N/A	0.0001	mg/L	N/A	2016-12-21	
Tin, dissolved	< 0.0002	N/A	0.0002	mg/L	N/A	2016-12-21	
Titanium, dissolved	< 0.005	N/A	0.005	mg/L	N/A	2016-12-21	
Uranium, dissolved	0.00238	N/A	0.00002	mg/L	N/A	2016-12-21	
Vanadium, dissolved	< 0.001	N/A	0.001	mg/L	N/A	2016-12-21	
Zinc, dissolved	0.026	N/A	0.004	mg/L	N/A	2016-12-21	
Zirconium, dissolved	< 0.0001	N/A	0.0001	mg/L	N/A	2016-12-21	

Total Metals

Aluminum, total	< 0.005	OG < 0.1	0.005	mg/L	2016-12-15	2016-12-16	
Antimony, total	< 0.0001	MAC = 0.006	0.0001	mg/L	2016-12-15	2016-12-16	
Arsenic, total	< 0.0005	MAC = 0.01	0.0005	mg/L	2016-12-15	2016-12-16	
Barium, total	< 0.005	MAC = 1	0.005	mg/L	2016-12-15	2016-12-16	
Beryllium, total	< 0.0001	N/A	0.0001	mg/L	2016-12-15	2016-12-16	
Bismuth, total	< 0.0001	N/A	0.0001	mg/L	2016-12-15	2016-12-16	
Boron, total	0.010	MAC = 5	0.004	mg/L	2016-12-15	2016-12-16	
Cadmium, total	< 0.00001	MAC = 0.005	0.00001	mg/L	2016-12-15	2016-12-16	
Calcium, total	54.1	N/A	0.2	mg/L	2016-12-15	2016-12-16	
Chromium, total	0.0008	MAC = 0.05	0.0005	mg/L	2016-12-15	2016-12-16	
Cobalt, total	< 0.00005	N/A	0.00005	mg/L	2016-12-15	2016-12-16	
Copper, total	0.0062	AO ≤ 1	0.0002	mg/L	2016-12-15	2016-12-16	
Iron, total	< 0.01	AO ≤ 0.3	0.01	mg/L	2016-12-15	2016-12-16	
Lead, total	0.0002	MAC = 0.01	0.0001	mg/L	2016-12-15	2016-12-16	
Lithium, total	0.0037	N/A	0.0001	mg/L	2016-12-15	2016-12-16	
Magnesium, total	27.2	N/A	0.01	mg/L	2016-12-15	2016-12-16	
Manganese, total	< 0.0002	AO ≤ 0.05	0.0002	mg/L	2016-12-15	2016-12-16	
Mercury, total	< 0.00002	MAC = 0.001	0.00002	mg/L	2016-12-18	2016-12-19	
Molybdenum, total	0.0002	N/A	0.0001	mg/L	2016-12-15	2016-12-16	
Nickel, total	< 0.0002	N/A	0.0002	mg/L	2016-12-15	2016-12-16	
Phosphorus, total	< 0.02	N/A	0.02	mg/L	2016-12-15	2016-12-16	
Potassium, total	0.76	N/A	0.02	mg/L	2016-12-15	2016-12-16	
Selenium, total	< 0.0005	MAC = 0.05	0.0005	mg/L	2016-12-15	2016-12-16	
Silicon, total	6.0	N/A	0.5	mg/L	2016-12-15	2016-12-16	
Silver, total	< 0.00005	N/A	0.00005	mg/L	2016-12-15	2016-12-16	
Sodium, total	4.24	AO ≤ 200	0.02	mg/L	2016-12-15	2016-12-16	
Strontium, total	0.410	N/A	0.001	mg/L	2016-12-15	2016-12-16	
Sulfur, total	7	N/A	1	mg/L	2016-12-15	2016-12-16	

REPORTED TO PROJECT Regional District of Thompson Nicola
Maple Mission CWS

WORK ORDER REPORTED 6120869
2016-12-21

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Maple Mission CWS - Pumphouse (6120869-01) [Water] Sampled: 2016-12-12 11:30, Continued

F1, FILT, PRES

Total Metals, Continued

Tellurium, total	< 0.0002	N/A	0.0002	mg/L	2016-12-15	2016-12-16	
Thallium, total	< 0.00002	N/A	0.00002	mg/L	2016-12-15	2016-12-16	
Thorium, total	< 0.0001	N/A	0.0001	mg/L	2016-12-15	2016-12-16	
Tin, total	< 0.0002	N/A	0.0002	mg/L	2016-12-15	2016-12-16	
Titanium, total	< 0.005	N/A	0.005	mg/L	2016-12-15	2016-12-16	
Uranium, total	0.00272	MAC = 0.02	0.00002	mg/L	2016-12-15	2016-12-16	
Vanadium, total	< 0.001	N/A	0.001	mg/L	2016-12-15	2016-12-16	
Zinc, total	0.023	AO ≤ 5	0.004	mg/L	2016-12-15	2016-12-16	
Zirconium, total	< 0.0001	N/A	0.0001	mg/L	2016-12-15	2016-12-16	

Volatile Organic Compounds (VOC)

Bromodichloromethane	0.001	N/A	0.001	mg/L	N/A	2016-12-17	
Bromoform	< 0.001	N/A	0.001	mg/L	N/A	2016-12-17	
Chloroform	0.006	N/A	0.001	mg/L	N/A	2016-12-17	
Dibromochloromethane	< 0.001	N/A	0.001	mg/L	N/A	2016-12-17	
Surrogate: Toluene-d8	101		70-130	%	N/A	2016-12-17	
Surrogate: 4-Bromofluorobenzene	99		70-130	%	N/A	2016-12-17	

Sample / Analysis Qualifiers:

CT5 This sample has been incorrectly preserved for Mercury analysis
 F1 The sample was not field-filtered and was therefore filtered through a 0.45 µm membrane in the laboratory and preserved with HNO3 prior to analysis for dissolved metals.
 FILT Sample has been filtered for Diss Hg in the laboratory.
 PRES Sample has been preserved for Diss Hg in the laboratory and the holding time has been extended.