



Date: 05-JUN-20

PO No.:

WO No.: L2451962

LSD:

Project Ref: SAVONA WTP

Sample ID: SAVONA TREATMENT PLANT

Sampled By:

Date Collected: 26-MAY-20

Lab Sample ID: L2451962-1

Matrix: Water

THOMPSON NICOLA REGIONAL DISTRICT
300 - 465 Victoria Street
Kamloops BC V2C 2A9
ATTN: Tyrone McCabe

PAGE 1 of 4

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Physical Tests						
UV Absorbance (254 nm), Unfiltered	0.131		Abs/cm			29-MAY-20
Colour, True	15.0		CU		15	28-MAY-20
Hardness (as CaCO3)	51.1		mg/L		500	05-JUN-20
Transmittance @ 254 NM, Un-Filtered	74.0		%T/cm			01-JUN-20
Organic / Inorganic Carbon						
Total Organic Carbon	3.91		mg/L			28-MAY-20
Total Metals						
Aluminum (Al)-Total	0.141		mg/L		0.1	03-JUN-20
Antimony (Sb)-Total	<0.00010		mg/L	0.006		03-JUN-20
Arsenic (As)-Total	0.00022		mg/L	0.01		03-JUN-20
Barium (Ba)-Total	0.0105		mg/L	2		03-JUN-20
Beryllium (Be)-Total	<0.00010		mg/L			04-JUN-20
Bismuth (Bi)-Total	<0.000050		mg/L			03-JUN-20
Boron (B)-Total	<0.010		mg/L	5		04-JUN-20
Cadmium (Cd)-Total	0.0000078		mg/L	0.005		03-JUN-20
Calcium (Ca)-Total	14.6		mg/L			03-JUN-20
Cesium (Cs)-Total	0.000025		mg/L			03-JUN-20
Chromium (Cr)-Total	0.00034		mg/L	0.05		03-JUN-20
Cobalt (Co)-Total	0.00013		mg/L			03-JUN-20
Copper (Cu)-Total	0.00249		mg/L	2.0	1.0	03-JUN-20
Iron (Fe)-Total	0.201		mg/L		0.3	03-JUN-20
Lead (Pb)-Total	0.000304		mg/L	0.005		03-JUN-20
Lithium (Li)-Total	0.0011		mg/L			03-JUN-20
Magnesium (Mg)-Total	4.06		mg/L			03-JUN-20
Manganese (Mn)-Total	0.00866		mg/L	0.12	0.02	03-JUN-20
Mercury (Hg)-Total	<0.0000050		mg/L	0.001		29-MAY-20
Molybdenum (Mo)-Total	0.00136		mg/L			03-JUN-20
Nickel (Ni)-Total	0.00096		mg/L			03-JUN-20
Phosphorus (P)-Total	<0.050		mg/L			03-JUN-20
Potassium (K)-Total	1.06		mg/L			03-JUN-20
Rubidium (Rb)-Total	0.00148		mg/L			03-JUN-20
Selenium (Se)-Total	0.000151		mg/L	0.05		03-JUN-20
Silicon (Si)-Total	3.43		mg/L			03-JUN-20
Silver (Ag)-Total	<0.000010		mg/L			03-JUN-20
Sodium (Na)-Total	4.11		mg/L		200	03-JUN-20
Strontium (Sr)-Total	0.0934		mg/L	7		03-JUN-20
Sulfur (S)-Total	4.24		mg/L			03-JUN-20
Tellurium (Te)-Total	<0.00020		mg/L			03-JUN-20
Thallium (Tl)-Total	<0.000010		mg/L			03-JUN-20
Thorium (Th)-Total	<0.00010		mg/L			03-JUN-20
Tin (Sn)-Total	<0.00010		mg/L			03-JUN-20
Titanium (Ti)-Total	0.00646		mg/L			03-JUN-20

ADDRESS: 1445 McGill Rd, Unit 2B, Kamloops BC, V2C 6K7 | Phone: +1 250 372 3588 | Fax: +1 250 372 3670

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 05-JUN-20

PO No.:

WO No.: L2451962

LSD:

Project Ref: SAVONA WTP

Sample ID: SAVONA TREATMENT PLANT

Sampled By:

Date Collected: 26-MAY-20

Lab Sample ID: L2451962-1

Matrix: Water

THOMPSON NICOLA REGIONAL DISTRICT
300 - 465 Victoria Street
Kamloops BC V2C 2A9
ATTN: Tyrone McCabe

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Tungsten (W)-Total	<0.00010		mg/L			03-JUN-20
Uranium (U)-Total	0.000478		mg/L	0.02		03-JUN-20
Vanadium (V)-Total	0.00069		mg/L			03-JUN-20
Zinc (Zn)-Total	0.0076		mg/L		5.0	03-JUN-20
Zirconium (Zr)-Total	<0.00020		mg/L			03-JUN-20
Dissolved Metals						
Dissolved Mercury Filtration Location	FIELD					30-MAY-20
Dissolved Metals Filtration Location	FIELD					02-JUN-20
Aluminum (Al)-Dissolved	0.0283		mg/L		0.1	05-JUN-20
Antimony (Sb)-Dissolved	<0.00010		mg/L	0.006		05-JUN-20
Arsenic (As)-Dissolved	0.00016		mg/L	0.01		05-JUN-20
Barium (Ba)-Dissolved	0.00911		mg/L	2		05-JUN-20
Beryllium (Be)-Dissolved	<0.00010		mg/L			05-JUN-20
Bismuth (Bi)-Dissolved	<0.000050		mg/L			05-JUN-20
Boron (B)-Dissolved	<0.010		mg/L	5		05-JUN-20
Cadmium (Cd)-Dissolved	<0.0000050		mg/L	0.005		05-JUN-20
Calcium (Ca)-Dissolved	13.5		mg/L			05-JUN-20
Cesium (Cs)-Dissolved	<0.000010		mg/L			05-JUN-20
Chromium (Cr)-Dissolved	<0.00010		mg/L	0.05		05-JUN-20
Cobalt (Co)-Dissolved	<0.00010		mg/L			05-JUN-20
Copper (Cu)-Dissolved	0.00161		mg/L	2.0	1.0	05-JUN-20
Iron (Fe)-Dissolved	0.039		mg/L		0.3	05-JUN-20
Lead (Pb)-Dissolved	0.000121		mg/L	0.005		05-JUN-20
Lithium (Li)-Dissolved	<0.0010		mg/L			05-JUN-20
Magnesium (Mg)-Dissolved	4.24		mg/L			05-JUN-20
Manganese (Mn)-Dissolved	0.00153		mg/L	0.12	0.02	05-JUN-20
Mercury (Hg)-Dissolved	<0.0000050		mg/L	0.001		30-MAY-20
Molybdenum (Mo)-Dissolved	0.00119		mg/L			05-JUN-20
Nickel (Ni)-Dissolved	0.00062		mg/L			05-JUN-20
Phosphorus (P)-Dissolved	<0.050		mg/L			05-JUN-20
Potassium (K)-Dissolved	1.05		mg/L			05-JUN-20
Rubidium (Rb)-Dissolved	0.00122		mg/L			05-JUN-20
Selenium (Se)-Dissolved	0.000140		mg/L	0.05		05-JUN-20
Silicon (Si)-Dissolved	3.36		mg/L			05-JUN-20
Silver (Ag)-Dissolved	<0.000010		mg/L			05-JUN-20
Sodium (Na)-Dissolved	4.37		mg/L		200	05-JUN-20
Strontium (Sr)-Dissolved	0.0941		mg/L	7		05-JUN-20
Sulfur (S)-Dissolved	4.02		mg/L			05-JUN-20
Tellurium (Te)-Dissolved	<0.00020		mg/L			05-JUN-20
Thallium (Tl)-Dissolved	<0.000010		mg/L			05-JUN-20
Thorium (Th)-Dissolved	<0.00010		mg/L			05-JUN-20
Tin (Sn)-Dissolved	<0.00010		mg/L			05-JUN-20

ADDRESS: 1445 McGill Rd, Unit 2B, Kamloops BC, V2C 6K7 | Phone: +1 250 372 3588 | Fax: +1 250 372 3670

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 05-JUN-20

PO No.:

WO No.: L2451962

LSD:

Project Ref: SAVONA WTP

Sample ID: SAVONA TREATMENT PLANT


Sampled By:

Date Collected: 26-MAY-20

Lab Sample ID: L2451962-1

Matrix: Water

THOMPSON NICOLA REGIONAL DISTRICT
300 - 465 Victoria Street
Kamloops BC V2C 2A9
ATTN: Tyrone McCabe

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Titanium (Ti)-Dissolved	0.00061		mg/L			05-JUN-20
Tungsten (W)-Dissolved	<0.00010		mg/L			05-JUN-20
Uranium (U)-Dissolved	0.000440		mg/L	0.02		05-JUN-20
Vanadium (V)-Dissolved	<0.00050		mg/L			05-JUN-20
Zinc (Zn)-Dissolved	0.0042		mg/L		5.0	05-JUN-20
Zirconium (Zr)-Dissolved	<0.00020		mg/L			05-JUN-20
Trihalomethanes						
Bromodichloromethane	0.0014		mg/L			01-JUN-20
Bromoform	<0.0010		mg/L			01-JUN-20
Dibromochloromethane	<0.0010		mg/L			01-JUN-20
Chloroform	0.124		mg/L			01-JUN-20
Total THMs	0.125		mg/L	0.1		03-JUN-20
Haloacetic Acids						
Bromochloroacetic Acid	<1.0		ug/L			29-MAY-20
Dibromoacetic Acid	<1.0		ug/L			29-MAY-20
Dichloroacetic Acid	40.6		ug/L			29-MAY-20
Total Haloacetic Acids 5	115		ug/L			29-MAY-20
Bromoacetic Acid	<1.0		ug/L			29-MAY-20
Chloroacetic acid	<5.0		ug/L			29-MAY-20
Trichloroacetic Acid	74.4	DLHC	ug/L			29-MAY-20
CDWQG = Health Canada Guideline Limits updated JUNE 2019						
<p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit.</p> <p>* Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality</p> <p>- A blank entry designates no known limit.</p> <p>- A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by </p> <p>Amanda Lampreau Account Manager</p>						

ADDRESS: 1445 McGill Rd, Unit 2B, Kamloops BC, V2C 6K7 | Phone: +1 250 372 3588 | Fax: +1 250 372 3670

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

Guidelines & Objectives

Sample Parameter Qualifier key listed:

Qualifier	Description
DLHC	Detection Limit Raised: Dilution required due to high concentration of test analyte(s).

Health Canada MAC Health Related Criteria Limits

Nitrate/Nitrite-N*	Criteria limit is 10 mg/L (1.0 mg/L if present as all Nitrite-N). High concentrations may contribute to blue baby syndrome in infants.
Lead*	A cumulative body poison, uncommon in naturally occurring hard waters.
Fluoride*	Present in fluoridated water supplies at 0.8 mg/L to reduce dental caries. Elevated levels causes fluorosis (mottling of teeth).
Total Coliforms*	Criteria is 0 CFU/100mL. Adverse health effects.
E. Coli*	Criteria is 0 CFU/100 mL. Certain E. Coli bacteria can be life threatening.
Manganese*	Criteria limit is 0.12 mg/L. Possible neurological effects in infants.

*Health Canada Canadian Drinking Water Quality Guidelines (MAC limit)

Aesthetic Objective Concentration Levels

Alkalinity	Acid neutralizing capacity. Usually a measure of carbonate and bicarbonates and calculated and reported as calcium carbonate.
Balance	Quality control parameter ratioing cations to anions
Bicarbonate	See Alkalinity. Report as the anion HCO ₃ -1
Carbonate	See Alkalinity. Reported at the anion CO ₃ -2
Calcium	See Hardness. Common major cation of water chemistry.
Chloride	Common major anion of water chemistry.
Conductance	Physical test measuring water salinity (dissolved ions or solids)
Hardness	Classical measure or capacity of water to precipitate soap (chiefly calcium and magnesium ions). Causes scaling tendency in water if carbonates/bicarbonates are present (if >200 mg/L). For drinking water purposes waters with results <200 mg/L are considered acceptable, results >200 mg/L are considered poor but can be tolerated. Results >500 mg/L are unacceptable.
Hydroxide	See alkalinity
Magnesium	See hardness. Common major cation of water chemistry. Elevated levels (>125 mg/L) may exert a cathartic or diuretic action.
pH	Measure of water acidity/alkalinity. Normal range is 7.0-8.5.
Potassium	Common major cation of water chemistry.
Sodium	Common major cation of water chemistry. Measure of salinity (saltiness).
Sulphate	Common major anion of water chemistry. Elevated levels may exert a cathartic or diuretic action.
Total Dissolved Solids	A measure of water salinity.
Iron	Causes staining to laundry and porcelain and astringent taste. Oxidizes to red-brown precipitate on exposure to air.
Heterotrophic Plate Count	Criteria is 500 cfu/mL Measure of heterotrophic bacteria present.

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.



Attach ALS barcode label here
(lab use only)

Contact and company name below will appear on the final report

Report Format / Distribution

Select Service Level Below - Please confirm all EAP TATs with your AM - surcharges will apply

Company: Thompson Nicola Regional District

Select Report Format: PDF EXCEL EBD (DIGITAL)

Regular [R] Standard TAT if received by 3 pm - business days - no surcharges apply

Contact: Tyone McCabe
250-377-8673

Quality Control (QC) Report with Report YES NO

4 day [P4]
3 day [P3]
2 day [P2]

Company address below will appear on the final report

Compare Results to Criteria on Report - provide details below if fax checked

EMERGENCY
1 Business day [E1]
Same Day, Weekend or Statutory holiday [E0]

Street: 300 - 465 Victoria St

Select Distribution: EMAIL MAIL FAX

Date and Time Required for all EAP TATs: _____

City/Province: Kamloops BC

Email 1 or Fax: skralchmer@tnd.ca

Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FP) below

Postal Code: V2C 2A9

Email 2: tmcabce@tnd.ca

Analysis Request

Invoice To: Same as Report To YES NO

Invoice Distribution: EMAIL MAIL FAX

Company: Thompson Nicola Regional District

Select Invoice Distribution: EMAIL MAIL FAX

Contact: Accounts Payable

Email 1 or Fax: finance@tnd.ca

ALS Account # / Quote #: TNR100 Q79867

Oil and Gas Required Fields (client use)

Job #: Savona WTP

AFECost Center: _____

PO / AFE: _____

Major/Minor Code: _____

LSD: _____

Requisitioner: _____

ALS Lab Work Order # (lab use only)

ALS Contact: Amanda Lampron

Sample Identification and/or Coordinates (This description will appear on the report)

Date (dd-mm-yy)

Sampler: _____

Savona Treatment Plant

Time (hh:mm)

Sample Type: Water

L2451962-COFC

Barcode

Drinking Water (DW) Samples¹ (client use)

Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)

Ate samples taken from a Regulated DW System?
 YES NO

Sample Condition as Received (lab use only)

Ate samples for human drinking water use?
 YES NO

Frozen
Ice Packs
Cooling Initiated

SHIPPING RELEASE (client use)

INITIAL SHIPMENT RECEPTION (lab use only)

SIF Observations Yes No
Custody seal intact Yes No

Released by: Dale Stuchowick

INITIAL SHIPMENT RECEPTION (lab use only)

INITIAL COOLER TEMPERATURES °C: 14
FINAL COOLER TEMPERATURES °C: 13

Date: 26/5/20

Time: 11:35

Received by: _____

Time: 11:35

Date: MAY 26 9:20

Received by: _____

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY

YELLOW - CLIENT COPY

Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

Number of Containers