

REPORTED TO Regional District of Thompson Nicola
300 - 465 Victoria Street
Kamloops, BC V2C 2A9

TEL 1-250-377-8673
FAX 1-250-374-6489

ATTENTION Shawn Kratchmer

WORK ORDER 3071196

PO NUMBER 23929
PROJECT Spences Bridge CWS
PROJECT INFO

RECEIVED / TEMP Jul-18-13 09:10 / 19.0 °C
REPORTED Jul-25-13
COC NUMBER 17208

General Comments:

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.

Issued By:



Jennifer Shanko, ASCT
Administration Coordinator, Kelowna

Please contact CARO if more information is needed or to provide feedback on our services.

Locations:

#110 4011 Viking Way
Richmond, BC V6V 2K9
Tel: 604-279-1499 Fax: 604-279-1599

#102 3677 Highway 97N
Kelowna, BC V1X 5C3
Tel: 250-765-9646 Fax: 250-765-3893

17225 109 Avenue
Edmonton, AB T5S 1H7
Tel: 780-489-9100 Fax: 780-489-9700

www.caro.ca

REPORTED TO PROJECT Regional District of Thompson Nicola
Spences Bridge CWS

WORK ORDER REPORTED 3071196
Jul-25-13

Analysis Description	Method Reference (* = modified from)		Location
	Preparation	Analysis	
Alkalinity, speciated	N/A	APHA 2320 B	Kelowna
Ammonia-N, total colorimetric	N/A	APHA 4500-NH3 G	Kelowna
Chloride in Water by IC	N/A	APHA 4110 B	Kelowna
Colour, True at 410 nm	N/A	APHA 2120 C *	Kelowna
Conductivity in Water	N/A	APHA 2510 B	Kelowna
Dissolved Metals	APHA 3030 B	APHA 3125 B	Richmond
Fluoride in Water by IC	N/A	APHA 4110 B	Kelowna
Hardness as CaCO3 (CALC)	N/A	APHA 2340 B	Richmond
Nitrate-N in Water by IC	N/A	APHA 4110 B	Kelowna
Nitrite-N in Water by IC	N/A	APHA 4110 B	Kelowna
Sulfate in Water by IC	N/A	APHA 4110 B	Kelowna
Total Dissolved Solids	N/A	APHA 2540 C	Kelowna
Total Recoverable Metals	APHA 3030E *	APHA 3125 B	Richmond
Transmissivity at 254nm	N/A	APHA 5910 B	Kelowna
Trihalomethanes	EPA 5030B / 5021A	APHA 6200 B	Richmond

Note: The numbers in brackets represent the year that the method was published/approved

Method Reference Descriptions:

APHA Standard Methods for the Examination of Water and Wastewater, American Public Health Association
EPA United States Environmental Protection Agency Test Methods

Glossary of Terms:

MRL Method Reporting Limit
< Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
AO Aesthetic objective
MAC Maximum acceptable concentration (health-related guideline)
% Percent W/W
Color Unit Colour referenced against a platinum cobalt standard
mg/L Milligrams per litre
uS/cm Microsiemens per centimeter

SAMPLE ANALYTICAL DATA

REPORTED TO PROJECT Regional District of Thompson Nicola
Spences Bridge CWS

WORK ORDER REPORTED 3071196
Jul-25-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

Anions

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00 =FILT, PRES

Alkalinity, Total as CaCO ₃	162		1 mg/L		N/A	Jul-18-13	
Alkalinity, Phenolphthalein as CaCO ₃	< 1		1 mg/L		N/A	Jul-18-13	
Alkalinity, Carbonate as CaCO ₃	< 1		1 mg/L		N/A	Jul-18-13	
Alkalinity, Bicarbonate as CaCO ₃	162		1 mg/L		N/A	Jul-18-13	
Alkalinity, Hydroxide as CaCO ₃	< 1		1 mg/L		N/A	Jul-18-13	
Chloride	9.01	AO ≤ 250	0.10 mg/L		N/A	Jul-20-13	
Fluoride	< 0.10	MAC = 1.5	0.10 mg/L		N/A	Jul-20-13	
Nitrogen, Nitrate as N	0.405	MAC = 10	0.010 mg/L		N/A	Jul-20-13	
Nitrogen, Nitrite as N	0.044	MAC = 1	0.010 mg/L		N/A	Jul-20-13	
Sulfate	100	AO ≤ 500	1.0 mg/L		N/A	Jul-20-13	

General Parameters

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00 =FILT, PRES

Colour, True	< 5	AO ≤ 15	5 Color Unit		N/A	Jul-19-13	
Conductivity (EC)	532		2 uS/cm		N/A	Jul-18-13	
Nitrogen, Ammonia as N, Total	0.025		0.020 mg/L		N/A	Jul-19-13	
Solids, Total Dissolved	330	AO ≤ 500	5 mg/L		N/A	Jul-22-13	
UV Transmittance @ 254nm	92.9		0.1 %		N/A	Jul-24-13	

Calculated Parameters

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00 =FILT, PRES

Total Trihalomethanes	0.020	0.1	0.004 mg/L		N/A	N/A	
Total Trihalomethanes (as CHCl ₃)	0.019		0.003 mg/L		N/A	N/A	
Hardness, Total (Total as CaCO ₃)	244		5.0 mg/L		N/A	N/A	
Hardness, Total (Diss. as CaCO ₃)	227		5.0 mg/L		N/A	N/A	
Nitrogen, Nitrate+Nitrite as N	0.449		0.020 mg/L		N/A	N/A	

Dissolved Metals

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00 =FILT, PRES

Aluminum, dissolved	< 0.05		0.05 mg/L		N/A	Jul-19-13	
Antimony, dissolved	< 0.001		0.001 mg/L		N/A	Jul-19-13	
Arsenic, dissolved	< 0.005		0.005 mg/L		N/A	Jul-19-13	
Barium, dissolved	< 0.05		0.05 mg/L		N/A	Jul-19-13	
Beryllium, dissolved	< 0.001		0.001 mg/L		N/A	Jul-19-13	
Bismuth, dissolved	< 0.001		0.001 mg/L		N/A	Jul-19-13	
Boron, dissolved	0.52		0.04 mg/L		N/A	Jul-19-13	
Cadmium, dissolved	< 0.0001		0.0001 mg/L		N/A	Jul-19-13	
Calcium, dissolved	55		2 mg/L		N/A	Jul-19-13	
Chromium, dissolved	< 0.005		0.005 mg/L		N/A	Jul-19-13	
Cobalt, dissolved	< 0.0005		0.0005 mg/L		N/A	Jul-19-13	
Copper, dissolved	0.042		0.002 mg/L		N/A	Jul-19-13	
Iron, dissolved	< 0.1		0.1 mg/L		N/A	Jul-19-13	

SAMPLE ANALYTICAL DATA

REPORTED TO PROJECT Regional District of Thompson Nicola
Spences Bridge CWS

WORK ORDER REPORTED 3071196
Jul-25-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

Dissolved Metals, Continued

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00, \bar{F} ILT, PRES
Continued

Lead, dissolved	< 0.001		0.001	mg/L	N/A	Jul-19-13	
Lithium, dissolved	0.003		0.001	mg/L	N/A	Jul-19-13	
Magnesium, dissolved	22.1		0.1	mg/L	N/A	Jul-19-13	
Manganese, dissolved	< 0.002		0.002	mg/L	N/A	Jul-19-13	
Mercury, dissolved	< 0.0002		0.0002	mg/L	N/A	Jul-19-13	
Molybdenum, dissolved	0.003		0.001	mg/L	N/A	Jul-19-13	
Nickel, dissolved	< 0.002		0.002	mg/L	N/A	Jul-19-13	
Phosphorus, dissolved	< 0.2		0.2	mg/L	N/A	Jul-19-13	
Potassium, dissolved	2.4		0.2	mg/L	N/A	Jul-19-13	
Selenium, dissolved	< 0.005		0.005	mg/L	N/A	Jul-19-13	
Silicon, dissolved	8		5	mg/L	N/A	Jul-19-13	
Silver, dissolved	< 0.0005		0.0005	mg/L	N/A	Jul-19-13	
Sodium, dissolved	26.9		0.2	mg/L	N/A	Jul-19-13	
Strontium, dissolved	0.38		0.01	mg/L	N/A	Jul-19-13	
Sulfur, dissolved	32		10	mg/L	N/A	Jul-19-13	
Tellurium, dissolved	< 0.002		0.002	mg/L	N/A	Jul-19-13	
Thallium, dissolved	< 0.0002		0.0002	mg/L	N/A	Jul-19-13	
Thorium, dissolved	< 0.001		0.001	mg/L	N/A	Jul-19-13	
Tin, dissolved	< 0.002		0.002	mg/L	N/A	Jul-19-13	
Titanium, dissolved	< 0.05		0.05	mg/L	N/A	Jul-19-13	
Uranium, dissolved	0.0018		0.0002	mg/L	N/A	Jul-19-13	
Vanadium, dissolved	< 0.01		0.01	mg/L	N/A	Jul-19-13	
Zinc, dissolved	< 0.04		0.04	mg/L	N/A	Jul-19-13	
Zirconium, dissolved	< 0.001		0.001	mg/L	N/A	Jul-19-13	

Total Recoverable Metals

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] Sampled: Jul-17-13 12:00 \bar{F} ILT, PRES

Aluminum, total	< 0.05	AO \leq 0.1	0.05	mg/L	Jul-19-13	Jul-20-13	
Antimony, total	< 0.001	MAC = 0.006	0.001	mg/L	Jul-19-13	Jul-20-13	
Arsenic, total	< 0.005	MAC = 0.01	0.005	mg/L	Jul-19-13	Jul-20-13	
Barium, total	< 0.05	MAC = 1	0.05	mg/L	Jul-19-13	Jul-20-13	
Beryllium, total	< 0.001		0.001	mg/L	Jul-19-13	Jul-20-13	
Bismuth, total	< 0.001		0.001	mg/L	Jul-19-13	Jul-20-13	
Boron, total	0.55	MAC = 5	0.04	mg/L	Jul-19-13	Jul-20-13	
Cadmium, total	< 0.0001	MAC = 0.005	0.0001	mg/L	Jul-19-13	Jul-20-13	
Calcium, total	59		2	mg/L	Jul-19-13	Jul-20-13	
Chromium, total	< 0.005	MAC = 0.05	0.005	mg/L	Jul-19-13	Jul-20-13	
Cobalt, total	< 0.0005		0.0005	mg/L	Jul-19-13	Jul-20-13	
Copper, total	0.042	AO \leq 1	0.002	mg/L	Jul-19-13	Jul-20-13	
Iron, total	< 0.1	AO \leq 0.3	0.1	mg/L	Jul-19-13	Jul-20-13	
Lead, total	< 0.001	MAC = 0.01	0.001	mg/L	Jul-19-13	Jul-20-13	
Lithium, total	0.003		0.001	mg/L	Jul-19-13	Jul-20-13	
Magnesium, total	23.7		0.1	mg/L	Jul-19-13	Jul-20-13	

REPORTED TO Regional District of Thompson Nicola
PROJECT Spences Bridge CWS

WORK ORDER 3071196
REPORTED Jul-25-13

Analyte	Result / Recovery	Canadian DW Guideline	MRL / Limit	Units	Prepared	Analyzed	Notes
---------	-------------------	-----------------------	-------------	-------	----------	----------	-------

Total Recoverable Metals, Continued

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] **Sampled:** Jul-17-13 12:00, **FILT, PRES**
Continued

Manganese, total	0.004	AO ≤ 0.05	0.002	mg/L	Jul-19-13	Jul-20-13	
Mercury, total	0.0003	MAC = 0.001	0.0002	mg/L	Jul-19-13	Jul-20-13	
Molybdenum, total	0.004		0.001	mg/L	Jul-19-13	Jul-20-13	
Nickel, total	< 0.002		0.002	mg/L	Jul-19-13	Jul-20-13	
Phosphorus, total	0.3		0.2	mg/L	Jul-19-13	Jul-20-13	
Potassium, total	2.6		0.2	mg/L	Jul-19-13	Jul-20-13	
Selenium, total	< 0.005	MAC = 0.01	0.005	mg/L	Jul-19-13	Jul-20-13	
Silicon, total	8		5	mg/L	Jul-19-13	Jul-20-13	
Silver, total	< 0.0005		0.0005	mg/L	Jul-19-13	Jul-20-13	
Sodium, total	28.4	AO ≤ 200	0.2	mg/L	Jul-19-13	Jul-20-13	
Strontium, total	0.40		0.01	mg/L	Jul-19-13	Jul-20-13	
Sulfur, total	49		10	mg/L	Jul-19-13	Jul-20-13	
Tellurium, total	< 0.002		0.002	mg/L	Jul-19-13	Jul-20-13	
Thallium, total	< 0.0002		0.0002	mg/L	Jul-19-13	Jul-20-13	
Thorium, total	< 0.001		0.001	mg/L	Jul-19-13	Jul-20-13	
Tin, total	< 0.002		0.002	mg/L	Jul-19-13	Jul-20-13	
Titanium, total	< 0.05		0.05	mg/L	Jul-19-13	Jul-20-13	
Uranium, total	0.0020	MAC = 0.02	0.0002	mg/L	Jul-19-13	Jul-20-13	
Vanadium, total	< 0.01		0.01	mg/L	Jul-19-13	Jul-20-13	
Zinc, total	< 0.04	AO ≤ 5	0.04	mg/L	Jul-19-13	Jul-20-13	
Zirconium, total	< 0.001		0.001	mg/L	Jul-19-13	Jul-20-13	

Volatile Organic Compounds (VOC)

Sample ID: Spences Bridge - Shawniken Sample Site (3071196-01) [Water] **Sampled:** Jul-17-13 12:00, **FILT, PRES**

Bromodichloromethane	0.003		0.001	mg/L	N/A	Jul-23-13	
Bromoform	< 0.001		0.001	mg/L	N/A	Jul-23-13	
Chloroform	0.017		0.001	mg/L	N/A	Jul-23-13	
Dibromochloromethane	< 0.001		0.001	mg/L	N/A	Jul-23-13	
Surrogate: Toluene-d8	89 %		80-120		N/A	Jul-23-13	
Surrogate: 4-Bromofluorobenzene	86 %		80-120		N/A	Jul-23-13	

Sample / Analysis Qualifiers:

FILT Sample has been filtered for Dissolved Metals in the laboratory.
PRES Sample has been preserved for Dissolved Metals in the laboratory and the holding time has been extended.